

THIS PERMIT IS SUBJECT TO THE ATTACHED SPECIAL CONDITIONS: 1 and 2

PERMIT ISSUED

DEPARTMENT OF ENVIRONMENTAL PROTECTION

JUN 14 2022



## Report of Analysis

Mail to: Spring Meadow Ranch Spring  
1486 Mount Wilson Road  
Lebanon PA 17042

Lab Number: 363664-01  
Date Reported: 06/08/2022

Public Water Supplier ID: 7386279

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
Sampled: 06/06/2022 12:22   Sampler: Derek High   Source: 101 Vending Tap   Spring Meadow Ranch Spring								
Bacteria-Total Coliform P	Absent	Pass	0	06/06/2022	14:44	dnb	SM 9223 Colilert	0
Bacteria - E.coli	Absent	Pass	0	06/06/2022	14:44	dnb	SM 9223 Colilert	0



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



This sample data will be forwarded to appropriate agencies to comply with monitoring requirements.

Report Approved By:

Andrew T Heist, Lab Technician