


SAN JUAN BASIN public health

281 Sawyer Drive
Durango, CO 81303

970 247 5702 | sjbpublichealth.org

Water Quality Laboratory | (970) 335-2039

Standard Bacteriological Test Results for Drinking Water

San Juan Basin Public Health 281 Sawyer Drive, Suite 300 Durango, CO 81303 (970) 335-2039		WATER BACTERIOLOGY		Fee Stamp 	
SAMPLE INFORMATION: PWSID NUMBER: <u>000</u> <input type="checkbox"/> COMMUNITY <input type="checkbox"/> NON-COMMUNITY <input checked="" type="checkbox"/> PRIVATE <input type="checkbox"/> ROUTINE <input type="checkbox"/> RAW <input type="checkbox"/> REPEAT FOR THE MONTH OF _____ <input type="checkbox"/> SPECIAL PURPOSE <input type="checkbox"/> FINISHED		DATE: <u>11/28/23</u> TIME: <u>10</u> BY: <u>mm</u> COLLECTED: <u>11/28/23</u> AM <input checked="" type="checkbox"/> PM <input type="checkbox"/> RELINQUISHED: _____ AM <input type="checkbox"/> PM <input type="checkbox"/>		RESULTS: SEE REVERSE FOR EXPLANATION TOTAL COLIFORM <input checked="" type="checkbox"/> PRESENT <input type="checkbox"/> ABSENT per 100ml E. COLI <input type="checkbox"/> PRESENT <input checked="" type="checkbox"/> ABSENT per 100ml 3214 2023 NOV 28 11:01 mm	
SYSTEM: <u>371 CR 500</u> SAMPLE SITE ADDRESS: <u>Boxfield</u> CITY: <u>La Plata</u> COUNTY: <u>La Plata</u> CHLORINE RESIDUAL: <input type="checkbox"/> FREE <input type="checkbox"/> TOTAL MG/L: _____		RESULTS SENT TO: <u>mail@crowbarcreek.com</u> (SAMPLES MAY NOT BE TESTED IF ALL INFORMATION IS NOT PROVIDED AND LEGIBLE)		LAB PROCEDURE: <input checked="" type="checkbox"/> Colliert-18 <input type="checkbox"/> Colliert-24 <input type="checkbox"/> Colisure-24 48 STD. MTH: 20th ED 9223C ANALYST: <u>mmh</u>	
TEST ORDERED: _____ BILL TO: _____		ults			

Total Coliform ABSENT: Coliform-type bacteria are either absent, or there is less than one Total Coliform colony growing per 100 mL. This is a microbiologically SAFE sample.

Total Coliform PRESENT: This is an UNSAFE sample, with greater than or equal to 1 Total Coliform colony per 100 mL. Water should be treated, retested, & confirmed safe.

E. Coli PRESENT: This is an UNSAFE sample. Water SHOULD NOT be used for drinking, cooking, or bathing until treated, retested, & confirmed safe.

***Your sample is INVALID and will NOT be tested IF:**

1. Greater than 30 hours old when received. Please resample and submit promptly.
2. Sample volume is not sufficient, or sample is overfilled. These cannot be processed accurately. Please note the 100 mL line on the bottle and resample.