

## CLIENT INFORMATION

Client: \*\*\*\*\*

Requested On: Dec 4, 2025

Phone: \*\*\*\*\*

Email: \*\*\*\*\*

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:

[support@mytapscore.com](mailto:support@mytapscore.com)

Do not contact facility technicians directly.

## TESTING PERFORMED

Testing Requested: VOC Water Test

Matrix: Drinking Water

Testing / Report ID: XMH2LT

Testing Facility: EMSL Analytical Inc

Facility Location: 200 Route 130 North

Cinnaminson, New Jersey 08077

## SAMPLE INFORMATION

Collection Date: Dec 10, 2025

Collected By: \*\*\*\*\*

Received Date: Dec 13, 2025

Reported On: Dec 22, 2025

Sample Location: Spring

Sample Address: \*\*\*\*\*

## TESTING NOTES FROM TAP SCORE

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact [support@mytapscore.com](mailto:support@mytapscore.com)

## SUMMARY ANALYSIS

ANALYTE	UNIT	RESULT	METHOD		EVALUATION
Total THMs	µg/L	NOT DETECTED			

## TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
1,1,1,2 Tetrachloroethane	µg/L	NOT DETECTED	0.16	0.5	EPA 524.2	No evaluation possible
1,1,1 Trichloroethane	µg/L	NOT DETECTED	0.16	0.5	EPA 524.2	No evaluation possible
1,1,2,2 Tetrachloroethane	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
1,1,2 Trichloroethane	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
1,1 Dichloroethane	µg/L	NOT DETECTED	0.16	0.5	EPA 524.2	No evaluation possible
1,1 Dichloroethylene	µg/L	NOT DETECTED	0.18	0.5	EPA 524.2	No evaluation possible
1,1 Dichloropropene	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
1,2,3 Trichlorobenzene	µg/L	NOT DETECTED	0.16	0.5	EPA 524.2	No evaluation possible
1,2,3 Trichloropropane	µg/L	NOT DETECTED	0.18	0.5	EPA 524.2	No evaluation possible
1,2,4 Trichlorobenzene	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
1,2,4 Trimethylbenzene	µg/L	NOT DETECTED	0.27	0.5	EPA 524.2	No evaluation possible
1,2 Dichlorobenzene	µg/L	NOT DETECTED	0.13	0.5	EPA 524.2	No evaluation possible
1,2 Dichloroethane	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
1,2 Dichloropropane	µg/L	NOT DETECTED	0.14	0.5	EPA 524.2	No evaluation possible
1,3,5 Trimethylbenzene	µg/L	NOT DETECTED	0.26	0.5	EPA 524.2	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

1,3 Dichlorobenzene	µg/L	NOT DETECTED	0.14	0.5	EPA 524.2	No evaluation possible
1,3 Dichloropropane	µg/L	NOT DETECTED	0.14	0.5	EPA 524.2	No evaluation possible
1,4 Dichlorobenzene	µg/L	NOT DETECTED	0.14	0.5	EPA 524.2	No evaluation possible
2,2 Dichloropropane	µg/L	NOT DETECTED	0.19	0.5	EPA 524.2	No evaluation possible
Benzene	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
Bromobenzene	µg/L	NOT DETECTED	0.14	0.5	EPA 524.2	No evaluation possible
Bromochloromethane	µg/L	NOT DETECTED	0.16	0.5	EPA 524.2	No evaluation possible
Bromodichloromethane	µg/L	NOT DETECTED	0.17	0.5	EPA 524.2	No evaluation possible
Bromoform	µg/L	NOT DETECTED	0.26	1	EPA 524.2	No evaluation possible
Bromomethane	µg/L	NOT DETECTED	0.35	0.5	EPA 524.2	No evaluation possible
Carbon Tetrachloride	µg/L	NOT DETECTED	0.17	0.5	EPA 524.2	No evaluation possible
Chlorobenzene	µg/L	NOT DETECTED	0.13	0.5	EPA 524.2	No evaluation possible
Chloroethane	µg/L	NOT DETECTED	0.21	0.5	EPA 524.2	No evaluation possible
Chloroform	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
Chloromethane	µg/L	NOT DETECTED	0.26	0.5	EPA 524.2	No evaluation possible
Chlorotoluene 2	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
Chlorotoluene 4	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
cis 1,2 Dichloroethylene	µg/L	NOT DETECTED	0.14	0.5	EPA 524.2	No evaluation possible
cis 1,3 Dichloropropene	µg/L	NOT DETECTED	0.16	0.5	EPA 524.2	No evaluation possible
Dibromochloromethane	µg/L	NOT DETECTED	0.2	0.5	EPA 524.2	No evaluation possible
Dibromochloropropane	µg/L	NOT DETECTED	0.3	0.5	EPA 524.2	No evaluation possible
Dibromomethane	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
Dichlorodifluoromethane	µg/L	NOT DETECTED	0.24	0.5	EPA 524.2	No evaluation possible
Dichloromethane	µg/L	NOT DETECTED	0.18	0.5	EPA 524.2	No evaluation possible
Ethylbenzene	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
Ethylene dibromide	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
Hexachlorobutadiene	µg/L	NOT DETECTED	0.19	0.5	EPA 524.2	No evaluation possible
Isopropylbenzene	µg/L	NOT DETECTED	0.21	0.5	EPA 524.2	No evaluation possible
Methyl Tertiary Butyl Ether	µg/L	NOT DETECTED	0.17	0.5	EPA 524.2	No evaluation possible
m,p Xylene	µg/L	NOT DETECTED	0.28	1	EPA 524.2	No evaluation possible
Naphthalene	µg/L	NOT DETECTED	0.25	0.5	EPA 524.2	No evaluation possible
n Butylbenzene	µg/L	NOT DETECTED	0.4	0.5	EPA 524.2	No evaluation possible
n Propylbenzene	µg/L	NOT DETECTED	0.22	0.5	EPA 524.2	No evaluation possible
o Xylene	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
p Isopropyltoluene	µg/L	NOT DETECTED	0.39	0.5	EPA 524.2	No evaluation possible
sec Butylbenzene	µg/L	NOT DETECTED	0.32	0.5	EPA 524.2	No evaluation possible
Styrene	µg/L	NOT DETECTED	0.23	0.5	EPA 524.2	No evaluation possible
tert Butylbenzene	µg/L	NOT DETECTED	0.22	0.5	EPA 524.2	No evaluation possible
Tetrachloroethylene	µg/L	NOT DETECTED	0.16	0.5	EPA 524.2	No evaluation possible
Toluene	µg/L	NOT DETECTED	0.12	0.5	EPA 524.2	No evaluation possible
trans 1,3 Dichloropropene	µg/L	NOT DETECTED	0.22	0.5	EPA 524.2	No evaluation possible
Trichloroethylene	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible
Trichlorofluoromethane	µg/L	NOT DETECTED	0.2	5	EPA 524.2	No evaluation possible
Vinyl Chloride	µg/L	NOT DETECTED	0.15	0.5	EPA 524.2	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

## **How To Read Your SimpleLab PDF Report**

*Your results are being evaluated against the Health Guidance Level.*

*This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.*

*MDL: The Method Detection Limit is the lowest concentration which the analysis team and instrumentation is configured to measure.*

*RL: The Method Reporting Limit is the lowest level at which the laboratory can confidently and accurately quantify the concentration.*

## How To Read Your SimpleLab PDF Report

Your results are being evaluated against the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team are configured to measure.



## Did you know?

This Tap Score report is easier to understand when viewed online. Access in-depth information about every detection, including health risks and treatment solutions.

[gosimplelab.com/signin](http://gosimplelab.com/signin)